



Arundel Fire-Rescue

468 Limerick Road
Arundel, Maine 04046
Phone:(207) 985.2572 Fax: (207) 985.6605

Jerry Beaulieu
Chief

Justin Cooper
Deputy Chief

Renald Tardif
Deputy Chief

October 11, 2022

Review of the Final Subdivision Application for the Goff Brook Farm Subdivision shows all requirements needed but does not seem to cover the Fire Protection requirement standards.

The indications of the type of water supply to be used for the sub-division. Evidence of adequate ground water supply shall be submitted by a well driller or a Hydrogeologist. Does this language refer to the placement of Residential Sprinklers?

A proposed 14 house sub-division requires the install of residential fire sprinkler system in all residential units in conformance with the standards of NFPA 13D.

Any proposed new residential development failing to meet the residential sprinkler standard shall be required the install of a concrete or polycarbonate cistern with a minimum of a 15,000-gallon capacity water tank.

As residential sprinkler systems are preferred choice of fire protection systems, please indicate which form fire protection system will be included in the Goff Brook Farm Subdivision. If you have any questions in regards of fire protection systems you may contact my office.

Respectfully,
Chief Beaulieu